

SHELL FINAL / OCCUPANCY FINAL INSPECTION GUIDELINES



Note: This is a list of items commonly inspected prior to building occupancy. Additional items or tests may be required, depending on the occupancy classification. Please refer to your "Conditions of Approval".

GENERAL INFORMATION

1. Address: approved size contrasting color and in approved location.
2. Fire extinguishers: approved size and type with Office of the Fire Marshal tag, mounted in approved method and location.
3. Fire lanes: per approved plans with approved signage.
4. Fire Department access: gates either electric (tested by Fire) or manual (with Knox Padlocks)
5. Fire hydrants: painted per county specifications and blue reflective markers.
6. Exit signs and emergency lighting: as per plans
7. NFPA 704 placards: as required
8. Knox rapid entry: Knox Box, Knox Haz-Mat Box, Knox Padlock or Knox keypad in approved locations
9. All required signage: Electrical Room, Mechanical Room, Fire Alarm Control Panel, Fire Sprinkler Riser and valves, Fire Pump Room, Roof Access and others as required.
10. Life Safety Systems: tested and operational; emergency generators, communication system, fire pump, smoke evacuation system, elevator operation and recall, delayed egress and magnetic door devices.

CHECKLIST

- Approved plans and "Conditions of Approval"
- Fire Sprinkler Final
- Fire Alarm Final
- Underground Water System Final & Flush
- UST / AST Tank Installation Final
- Fire Pump Final
- Spray Booth Final
- Hood & Duct Suppression System Final



MENIFEE FIRE DEPARTMENT · OFFICE OF THE FIRE MARSHAL
29844 Haun Road · Menifee, CA 92586 · (951) 246-6215 Fire General Line
Inspection Request Email menifeeofm@cityofmenifee.us

