



Riverside County Fire Department-INFORMATION BULLETIN IB#06-07

The Riverside County Fire Department Fire Protection Planning Section has developed and will apply the following requirements for fire sprinkler riser servicing accessibility to facilitate the maintenance of automatic fire sprinkler systems in accordance with Title 19, Sec. 901 and California Fire Code (CFC) Sec. 901.4.6.

Where provided, fire pump rooms and automatic sprinkler system riser rooms shall be designed with adequate space for all equipment necessary for the installation, as defined by the manufacturer, with sufficient working space around the stationary equipment. Clearances around equipment to elements of permanent construction, including other installed equipment and appliances, shall be sufficient to allow inspection, service, repair or replacement without removing such elements of permanent construction or disabling the function of a required fire-resistance-rated assembly. Fire pump and automatic sprinkler system riser rooms shall be provided with doors and unobstructed passageways large enough to allow removal of the largest piece of equipment.

Questions regarding specific applications should be directed to Menifee Fire Department-Office of the Fire Marshal.



MENIFEE FIRE DEPARTMENT · OFFICE OF THE FIRE MARSHAL
29844 Haun Road · Menifee, CA 92586 · (951) 246-6215 Fire General Line
Inspection Request Email menifeeofm@cityofmenifee.us

